



PUBLIC HEALTH ENGINEERING DEPARTMENT
LABORATORY JHUNJHUNU

CHEMICAL EXAMINATION REPORT OF WATER

No. Lab. / Chem. /2024-25/ 22

Date - 8.4.2024

To,
The Principal
Radhakrishna Birla School
Pilani
Ref- Yours letter dated 08-04-2024


Distt:- Jhunjhunu

Tehsil:-Pilani

Date of Exam -08-04-2024

| A | Name & Location of Source | IS-10500:2012 | | Water Sample Radhakrishna Birla School | |
|--------|--|------------------|--------------------|--|--|
| B | Village/ Town | | | Jhunjhunu | |
| C | Date Of Collection | | | 08-02-2024 | |
| D | Lab. Sample No. | | | C-003 | |
| Sr. No | Parameters | Desirable limits | Permissible limits | Value | |
| 1 | pH | 6.5—8.5 | 6.5—8.5 | 7.42 | |
| 2 | Turbidity[NTU] | 1 | 5 | Nil | |
| 3 | Temperature[C] | ----- | ----- | 25 | |
| 4 | Colour[Units] | 5 Hazen Unit | 15 Hazen Unit | None | |
| 5 | Odour | Unobjectionable | Unobjectionable | Unobj. | |
| 6 | Total Alkalinity[asCaCO ₃] | 200 | 600 | 48 | |
| 7 | Total Hardness[asCaCO ₃] | 200 | 600 | 22 | |
| 8 | Calcium [asCa] | 75 | 200 | 4 | |
| 9 | Magnesium [as Mg] | 30 | 100 | 2.43 | |
| 10 | Chloride[asCl ⁻¹] | 250 | 1000 | 24 | |
| 11 | Nitrate[as NO ₃ ⁻¹] | 45 | 45 | 3 | |
| 12 | Fluoride [as F ⁻¹] | 1.0 | 1.5 | 0.12 | |
| 13 | TDS | 500 | 2000 | 105 | |

Note: All Results Except pH in mg/L.


(S K Sharma)
Junior Chemist
PHED Laboratory Jhunjhunu

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 22

Date : 8.4.2024

It is certified that an inspection team headed by Surendra Kumar Sharma
Junior chemist (Name of Officers with
designation) from PHED Laboratory Durgam (Name of
Department/Office) inspected the Radhakrishna Girls School
Pilani (Name & Address of the
School) on 8.4.2024 and found that the Radhakrishna Girls School
Pilani (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per the norms prescribed by the
Central/State/U.T Govt.

The above valid for a period of one year.

Signature with Seal : (सुरेन्द्र कुमार शर्मा)
Name : कनिष्ठ रसायनज्ञ
Designation : जन स्वा० अभि० विभाग
प्रयोगशाला, झुंझुनू

To Principal
Radhakrishna Girls School
Pilani

(Name & Address of the institution)